



वर्गीय आवश्यकताओं के लिए मानक

टीईसी ६६१७०:२०२५

STANDARD FOR GENERIC REQUIREMENTS

TEC 66170:2025

आउटडोर वेदर प्रूफ रैक फॉर टेलीकॉम इक्विपमेंट्स

Outdoor Weather Proof Rack For Telecom Equipments



ISO9001:2015

दूरसंचार अभियांत्रिकी केंद्र

खुरशीदलाल भवन, जनपथ, नई दिल्ली-110001, भारत

TELECOMMUNICATION ENGINEERING CENTRE

KHURSHIDLAL BHAWAN, JANPATH, NEW DELHI-110001, INDIA

www.tec.gov.in

© टीईसी, २०२५

© TEC, 2025

इस सर्वाधिकार सुरक्षित प्रकाशन का कोई भी हिस्सा, दूरसंचार अभियांत्रिकी केंद्र, नई दिल्ली की लिखित स्वीकृति के बिना, किसी भी रूप में या किसी भी प्रकार से जैसे -इलेक्ट्रॉनिक, मैकेनिकल,फोटोकॉपी, रिकॉर्डिंग, स्कैनिंग आदि रूप में प्रेषित, संग्रहीत या पुनरुत्पादित न किया जाए ।

All rights reserved and no part of this publication may be reproduced, stored in a retrieval system or transmitted, in any form and by any means - electronic, mechanical, photocopying, recording, scanning or otherwise, without written permission from the Telecommunication Engineering Centre, New Delhi.

Release 1: December, 2025

TEC Standard No. TEC 66170:2025

FOREWORD

Telecommunication Engineering Centre (TEC) is the technical arm of the Department of Telecommunications (DOT), Government of India. Its activities include:

- Framing of Standards for Generic Requirements for a Product/Equipment, Standards for Interface Requirements for a Product/Equipment, Standards for Service Requirements
- Formulation of Essential Requirements (ERs) under Mandatory Testing and Certification of Telecom Equipment (MTCTE) Policy
- Field evaluation of Telecom Products and Systems
- Designation of Conformity Assessment Bodies (CABs)/Testing facilities
- Testing & Certification of Telecom products
- Adoption of Standards
- Support to DoT on technical/technology issues

For the purpose of testing, four Regional Telecom Engineering Centers (RTECs) have been established which are located in New Delhi, Bangalore, Mumbai, and Kolkata.

ABSTRACT

This document contains the generic requirements of Outdoor weatherproof racks **to house telecom equipments**. As most of the telecom sites are now becoming outdoor, there are telecom equipments which are temperature and dust sensitive. To house such equipments, there is a need of rack which can provide suitable temperature controlled and dust free environment.

CONTENTS

<i>Clause No.</i>	<i>Particulars</i>	<i>Page No.</i>
	History Sheet	5
	References	6
CHAPTER 1		
1.0	Introduction	9
2.0	Functional Requirements.	9
3.0	Operational Requirements	9
4.0	Other Requirements	16
5.0	Quality Requirement	18
6.0	EMI/ EMC Requirements	21
7.0	Safety Requirements	24
CHAPTER 2		
8.0	Guidelines For the Purchaser	25
9.0	Ordering Information	28
10.0	Specific items to be mentioned in the certificate	28
11.0	Annexure-1: Remote Monitoring Communication Protocol – RS485 MODBUS	29
12.0	Abbreviations	35

HISTORY SHEET

<i>S. No.</i>	<i>Standard/ Document No.</i>	<i>Title</i>	<i>Remarks</i>
1	TEC 66170:2025	Outdoor Weather Proof Racks For Telecom Equipments	First issue

REFERENCE

<i>S. No.</i>	<i>Document No.</i>	<i>Title/Document Name</i>
1.	CISPR 32 (2015) with A1(2019)	Electromagnetic compatibility of multimedia equipment – Emission requirements.
2.	QM-115	Quality standard for calculation/verification of MTBF
3.	QM-118	Quality reliability in product design.
4.	QM-202	Pictorial guidelines for Visual assessment of quality of printed board assemblies (PBA) & discrete terminal assemblies.
5.	QM-204	Guidelines for workmanship standards for repair & modification of printed wiring board assemblies.
6.	QM-205	Guidelines for standard of workmanship for printed boards.
7.	QM-206	Guidelines for standard of workmanship for printed boards assemblies
8.	QM-207	Guidelines for soft solder and fluxes for Telecom Equipments.
9.	QM 210	Guidelines for standard of workmanship for surface Mounting Devices.
10.	TEC 14016:2010 (old no. QM-333:2010)	Standard for Environmental testing of Telecommunication equipment.
11.	ITU Rec. O.41	Psophomeric noise requirements.
12.	IS: 5	Standard on colors & shades.
13.	IS: 101	Methods of Sampling & Test for Paints, Varnishes & Related Products.
14.	IS: 168	Ready Mixed Paint, Air Drying, For General Purpose-Specification

15.	IS: 613	Standard on Bus-bars
16.	IS: 1248	Standard on Shunts.
17.	IS: 1359	Specification for Tinning requirements.
18.	IS: 1554 with Amend. -1 (June 1994)	Standard for Cables & Wires.
19.	IS 10437(1986)	Safety requirements for radio transmitting equipments” (equivalent to IEC 60215).
20.	ISO-9001-2000	Quality Management Systems Requirements.
21.	EN 61643 – 11 / A11	Low Voltage Surge Protective Device – Part 11: Surge Protective Device connected to low voltage power system – Requirement and Tests
22.	IEC 61000-4-18	Electromagnetic compatibility (EMC) - Part 4-18: Testing and measurement techniques - Damped oscillatory wave immunity test
23.	IEC 60215	Safety requirements for radio transmitting equipment - General requirements and terminology
24.	IEC 62305 – 1	Protection Against Lightning – Part 1: General Principle
25.	IEC 62305 – 2	Protection Against Lightning – Part 2: Risk Mgmt.
26.	IEC 62305 – 3	Protection against lightning – Part 3: Physical damage to structures and life hazard
27.	IEC 62305 – 4	Protection Against Lightning – Part 4: Electrical & Electronic System Within Structure
28.	IEC 60364 – 5 – 53	Electrical Installation Of Building – Part 5 – 53: Selection & Erection of Electrical Equipments
29.	IEC 61643- 1 (Second Edition 2005 – 03)	Low-voltage surge protective devices – Part 1: Surge protective devices connected to low-voltage power distribution systems – Requirements and tests

30.	IEC 60364-5-53: 2001 Amendment-1 2002 – 04	Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control
31.	TEC10009: 2024	Audio/video, information and communication technology equipment – Part 1: Safety requirements 'SAFETY REQUIREMENTS OF TELECOMMUNICATION EQUIPMENT':

Note:

Unless otherwise explicitly stated, the latest approved issue of the standard/GR/IR, with all amendments in force, listed in references, shall be applicable.

CHAPTER 1

1.0 INTRODUCTION:

- 1.1 This document contains the generic requirements of Outdoor weatherproof rack, which shall be suitable for operation from 48V power source like SMPS, Batteries, Solar Charge controller etc. It shall be at least IP55 protected and suitable for outdoor environment.

2.0 FUNCTIONAL REQUIREMENTS:

The Outdoor rack shall be equipped with

- a) Air-conditioner and/ or Heat Exchanger
- b) 19" or 21" channels / Purchaser specific mounting arrangement
- c) Purchaser specific DCDB
- d) Smoke sensor
- e) Door open sensor
- f) LED light for rack illumination

Note: - The purchaser shall specify the requirement of Heat Exchanger.

3.0 OPERATIONAL REQUIREMENTS

The operational requirements of an outdoor rack for telecom equipment are critical to ensuring the efficient and reliable functioning of the telecom infrastructure in outdoor environments. These requirements address the performance, maintenance, and management aspects of the outdoor rack. Here are some key operational requirements:

The requirements of the setup are as specified below:

3.1 Operational requirements of Outdoor rack:-

- 3.1.1 Weatherproof Rack:** The outdoor rack shall be designed to provide protection against environmental elements such as rain, dust, and temperature fluctuations. It shall be typically constructed with materials that offer durability and weather resistance. The ingress protection for Outdoor rack shall be of minimum IP-55 as per IEC60529 and the purchaser shall specify higher requirement i.e. above IP55 if required.
- 3.1.2 Usable space requirement for Telecom Equipment in Rack:** A 19-inch or 21-inch rack suitable for telecom equipment with usable space of maximum 42U. The depth of the Rack shall be of minimum 600mm. However, purchaser shall specify requirements depending upon telecommunication equipment. Mounting channels as per IEC60297 (or equivalent Indian/ETSI standard) are to be provided to install and secure telecommunications Equipment in rack cabinets.
- Usable space does not include the space occupied by DCDB.
- Usable U space can also be defined by purchaser at the time of purchase.
- For certification purpose (TSEC/ TAC etc.) approval purpose 42U space shall be considered.
- 3.1.3 Smoke Detectors:** The OEM/Manufacturer shall ensure to choose the smoke detectors, which operates at 48V DC and explicitly designed to be used inside the cabinet for outdoor use. The detectors are of good quality & built to withstand harsh environmental conditions, including temperature fluctuations, moisture and dust. Smoke detectors shall be operating for the temperature range -20°C to 80°C, Humidity: 0 to 95% RH with no condensation or icing.
- 3.1.4 Cabinet lifting arrangement:** Four number of Cabinet lifting hooks are to be provided for installing and removing equipment racks safely and efficiently.
- 3.1.5 Lock:** The outdoor rack shall be equipped with a metallic 4-point locking system.

3.1.6 Rack material: The outdoor rack shall be made of GI (Galvanized Iron) sheet duly powder coated (minimum 120 gsm).

3.1.7 Door & Cable entry: There should be only one door of the rack and that should be on the front side. Rack should be closed and sealed from all other sides to avoid cooling loss.

Cable entry shall be provided at bottom of the cabinet with MCT or similar sealing's. Size and number of cable glands shall be specified by the Purchaser / Procurer. For TAC/ any certification purpose, one minimum MCT size (12/12) or similar sealing shall be demonstrated, if not specifically mentioned by the purchaser / procurer.

For certification purpose (TSEC/ TAC etc.), total 6 nos. of cable glands should be provided in the rack as per following size and number: -

PG29 – 1 no.

PG16 – 1 no.

PG21 – 4nos.

3.1.8 Thermal insulation: Foam type & thickness are to be decided by the OEM/ Manufacturer for minimum solar gain and deration performance. Minimum of 19 mm for Air conditioning & 6 mm for Heat Exchanger Thermal insulation foam with Fire rated to be provided.

3.1.9 DCDB: It should be 19" in width. Following MCBs shall be provided:-

(a) **MCB for cooling unit** – OEM to ensure appropriate rating of MCB shall be provided for cooling unit DC input according to the power rating of cooling unit.

(b) **DC Load MCBs** – Rating and no. of MCBs shall be decided by purchaser.

For TSEC approval purpose, following MCBs shall be provided:-

MCB 16A – 2nos.

MCB 10A – 6 nos.

For +ve termination, suitable busbar or terminal block shall be provided.

3.1.10 Door open detection: The rack shall have provision to detect door open status and if door is open, rack light should automatically switch ON. An Industrial grade LED panel light shall be used for this requirement.

3.1.11 Earthing: The outdoor rack system must be diagonal earthing. Additionally, proper Earthing provisions shall be extended to the doors.

3.1.12 Potential free contacts: Following potential free contacts must be available in outdoor cabinet:

(a) Common cooling unit Alarm (Fan fail, Compressor fail, Internal temperature sensor fail, Ambient temperature sensor fail, Humidity, low temperature, Over Voltage, Under Voltage, etc.)

(b) High temperature inside the cabinet

(c) Cabinet door open

(d) Smoke alarm

All alarm shall be available on Remote monitoring protocol – RS485 Modbus as per Annexure 1

3.2 Operational requirement of Air conditioner cooling unit:

3.2.1 Air Conditioning Unit: An air conditioner suitable for outdoor deployment is to be supplied based on the cooling requirements of the Telecom equipment. The air-conditioner shall operate with 48V DC power source. Factors such as

capacity, energy efficiency, and environmental suitability are considered during the design Process.

3.2.2 Air Compressor: Compressors of air conditioning system shall be hermetically sealed type of high quality, very reliable, trouble free and with long operating life. Valves shall be provided for charging / topping up of refrigerant. The Purchaser / Procurer shall furnish the details of their compressors indicating the MTBF, life of the compressor and continuous run time of the compressors without failure. Compressor shall have minimum of 1 years Warranty from the date of commissioning. Purchaser shall specify the extended warranty if needed.

3.2.3 Microprocessor-based Controller: The operational requirements of a microprocessor-based controller are essential for ensuring efficient and effective control of the cooling system. Some of the key operational requirements are Temperature Control and Regulation, Energy Efficiency, display of Mode of operation, temperature setting and status of operation and various system alarms.

The air conditioning system shall have a microprocessor-based controller. The Controller shall be capable of displaying the real-time parameters:

3.2.4 Derating performance feature in air conditioner: In the context of cooling systems and air conditioning system, during occasional ambient temperature spikes, higher altitude levels, voltage fluctuations or environmental and installation conditions, a safety margin shall be incorporated into the system's design. For example, this means that the compressor shall continue to be in running condition at derating/ reduced cooling capacity even if the ambient temperature slightly exceeds the upper limit of 45°C, for a short time without compromising the safety of the compressor.

3.2.5 Monitoring and Control: RS485 port shall be available in cooling unit. Modbus communication is given in Annexure:-

3.2.6 Input Voltage working range: Cooling unit shall work satisfactorily from 42Vdc to 58Vdc.

- 3.2.7 Capacity:** Suitable capacity of Air Conditioning unit to be provided to maintain the desired temperature as per mutual agreement of purchaser and OEM. Air conditioner maintains lower temperature inside the cabinet w.r.t to ambient/outside cabinet temperature.
- 3.2.8 Unit operating temperature range:** Unit shall operate satisfactorily from -5°C to 55°C
- 3.2.9 Refrigerant:** Air Conditioning unit shall have R134a or R410 refrigerant.
- 3.2.10 Alarms & Parameters:** Following alarms should be displayed on Air Conditioning unit display:
1. High Temperature
 2. Low Temperature
 3. Humidity
 4. Over voltage
 5. Under voltage
 6. Compressor Fail
 7. Fan Fail
 8. Internal Temperature sensor fail.
 9. Ambient temperature sensor fail
 10. Cabinet door open
 11. Smoke alarm
- 3.3 Operational requirement of Heat Exchanger / Refrigerant based heat exchanger unit:**
- 3.3.1 Heat Exchanger Unit:** A heat exchanger suitable for outdoor deployment is to be supplied based on the cooling requirements of the Telecom equipment. The heat exchanger shall operate with 48V DC power source. Factors such as capacity, energy efficiency, and environmental suitability are considered during the design Process.
- 3.3.2 Microprocessor-based Controller:** The operational requirements of a microprocessor-based controller are essential for ensuring efficient and

effective control of the cooling system. Some of the key operational requirements are Temperature Control and Regulation, Energy Efficiency, display of Mode of operation, temperature setting and status of operation and various system alarms.

The heat exchanger system shall have a microprocessor-based controller. The Controller shall be capable of displaying the real-time parameters

- 3.3.3 Derating performance feature in Heat exchanger:** In the context of cooling systems, during occasional ambient temperature spikes, higher altitude levels, voltage fluctuations or environmental and installation conditions, a safety margin shall be incorporated into the system's design.
- 3.3.4 Monitoring and Control:** RS485 port shall be available in cooling unit. Modbus communication is given in Annexure:-
- 3.3.5 Input Voltage working range:** Cooling unit shall work satisfactorily from 42Vdc to 58Vdc.
- 3.3.6 Capacity:** Suitable capacity of heat exchanger to be provided to maintain temperature the desired temperature as per mutual agreement of purchaser and OEM. Heat exchanger maintains higher temperature inside the cabinet w.r.t to ambient/outside cabinet temperature.
- 3.3.7 Unit operating temperature range:** Unit shall operate satisfactorily from -5°C to 55°C
- 3.3.8 Refrigerant:** Air Conditioning unit shall have R134a refrigerant (only applicable for refrigerant based heat exchanger)
- 3.3.9 Alarms & Parameters:** Following alarms & Parameters shall be displayed on hex display:
1. High Temperature
 2. Low Temperature
 3. Humidity
 4. Over voltage
 5. Under voltage

6. Fan Fail
7. Internal Temperature sensor fail
8. Ambient temperature sensor fail
9. Cabinet door open
10. Smoke alarm

3.4 Operational life:

The outdoor rack unit shall have operational life of 10 years normally subjected to mutual AMC agreement between the Purchaser / procurer and the OEM / Manufacturer. These rack units shall be capable to be installed on the transmission tower on pan India basis in climatic conditions prevailing in India.

4.0 CONSTRUCTION

The outdoor rack system shall be completely self-contained, consisting of a single AC unit of rated capacity, which can be mounted on front door of the cabinet.

Good quality hinges shall be used for the doors to sustain the weight of the door and AC unit.

Door stoppers shall be provided to secure and control the movement of the doors of the rack enclosure.

The placement of air conditioning / Hex system should be such that the maintenance and repairing works of cooling unit shall be carried out without affecting the running of the telecom equipment.

The colour of the cabinet shall be Pure Polyester RAL 9016 glossy.

The system shall be assembled, wired, piped, charged with refrigerant, and fully factory tested to ensure trouble-free installation.

4.1 Layout: The layout of outdoor rack equipped with air-conditioner/Hex system shall be designed in such a way that it provides better circulation of the air

inside the cabinet to avoid any hot air pockets.

4.2 Cable & Wiring:

All the wires and cables including Uninyvin cables used shall be fire retardant as per IS 1554 with amendment 1 (June 94). All the cables & wires used shall also be Rodent & reptiles repellent. Uninyvin cables are also allowed to use in system.

4.3 Accessibility & Terminations

All the termination points shall be easily accessible from front with proper labelling and safety compliance.

4.4 Name Plate:

A name plate anodised, screen printed or any other better arrangement ensuring better life expectancy shall be suitably fixed inside / on shelf and contain following information:

1. TEC Standard Number:
2. Manufacturer's name:
3. Model No.:
4. Unit Serial No.:
5. TAC No.
6. Input Voltage:
7. Type of cooling and capacity:
8. Year & Month of manufacturing:

*Type of cooling shall be either "Air conditioner" or "Heat Exchanger"

4.5 Documentation:

Technical literature in English with complete layout, detailed block schematic and circuit diagrams of its assemblies shall be provided in hard copy. All aspects of installation, operation, maintenance, trouble shooting and replacement shall be covered in this manual. Additionally, a soft copy /QR code

on the system in respect of technical literature shall also be provided both in Hindi and English .This manual can be provided as a soft copy or QR code and/ or hard copy as specified by the purchaser / procurer. Label or suitable arrangement for address and telephone numbers of Maintenance centre shall also be provided.

4.6 REMOTE MONITORING COMMUNICATION PROTOCOL

Follow Annexure 1

5.0 QUALITY REQUIREMENTS

5.1 Components: The component parts of the equipment shall be of professional grade of reputed manufacturer to ensure prompt and continuous service and delivery of spare parts.

5.2 Power transformers and Chokes: Power transformers & chokes (if used) shall be class B or higher grade of insulation. The transformers and chokes shall be wound with copper wire and provided with adequate insulation.

5.3 Fuses or circuit breakers shall be provided wherever appropriate for the protection against failure of control/sensing circuit.

5.4 Quality and Workmanship: The equipment shall manufacture in accordance with international quality management systems ISO-9001-2015, for which the manufacturer shall be duly accredited. A quality plan describing the quality assurance system followed by the manufacturer would be required to be submitted.

5.4.1 The equipment shall be manufactured as per the latest Guidelines indicated in Quality Manuals QM-118 (Quality reliability in product design), Manuals QM-202 (Pictorial guidelines for Visual assessment of quality of printed board assemblies (PBA) and discrete terminal assemblies), QM-204 (Guidelines for workmanship standards for repair & modification of printed wiring board assemblies), QM-205 (Guidelines for standard of workmanship for printed

boards), QM-206 (Guidelines for standard of workmanship for printed boards assemblies), QM-207 (Guidelines for soft solder and fluxes for Telecom Equipments) and QM 210 (Guidelines for standard of workmanship for surface Mounting Devices).

5.4.2 All wiring shall be neatly secured in position and adequately supported. Metal panel or cover holes through which the wires or cables pass shall be suitably bushed.

5.5 BURN IN TEST: The fully equipped rack shall be capable of withstanding a burn-in test for 72 hours at an ambient temperature of 50°C when the equipment is working at full rated load. This test may be performed in a temperature controlled room with free air flow. The ambient temperature shall be measured at a distance of 1 foot from the equipment under test. The necessary set-up for the purpose shall be provided by the manufacturer.

5.5.1 The temperature rise of the heat dissipating components above the ambient, measured directly or at heat sink in the first eight hours of the test, shall not be more than:

5.5.2 Transformers and Chokes: 70°C for Grade B insulation.

For higher grade of insulation, higher temperature rise may be permissible, subject to the following conditions:

- i. It is at least 20°C below the permissible limit for the grade of insulation used.
- ii. The temperature rise shall be at least 30°C below Curie temperature of the magnetic material.
- iii. This temperature shall neither affect other components nor shall lead to fire hazard.

5.5.3 Semiconductor devices: 60°C or as per component spec.

5.6 Insulation Resistance Test: The insulation resistance of the complete System when tested with a 500V DC megger shall not be less than 5meg ohms for the following conditions:

- Interconnected Input terminals and Earth

- Interconnected Output terminals and Earth
- Interconnected Input terminals and Interconnected output terminals.

5.7 Voltage Proof Test: No breakdown or abnormal temperature rise shall occur, when-after EMI/RFI capacitors and MOVs/Tranzorbs etc. removed from the circuit - a test voltage of 2000V/50Hz is applied for one minute between :

- earth and interconnected output terminals.
- earth and interconnected input terminals.
- input and output terminals.

Alternatively, without removing EMI/RFI capacitors, the lightning protection circuitry and Tranzorbs etc., but with EMI/RFI discharge resistors removed:

- A 2150V DC can be applied for one minute between shorted AC output & DC input terminals.
- 650V DC can be applied for one minute between shorted AC Input terminals, shorted input DC terminals, shorted DC output terminals & earth.

This DC voltage test is in accordance with UL950 & IEC 950 Standards.

Note: This Test is to be conducted on each of the basic units of the system.

5.8 Noise & Vibration:

The fully equipped power shelf at full load shall not contribute more than 15 dB (weighted) to the ambient noise level taken as 45dBA. It shall be measured at a distance of 1 metre from the unit & 1.25m above the floor level in the Acoustic Range. The correction factor for Total Noise when the ambient noise level is more than 45dBA, shall be as given below:

Ambient Noise	Correction Factor	Ambient Noise	Correction Factor	Ambient Noise	Correction Factor
45dBA	0dB	51dBA	1.41dB	57dB	3.69dB
46dBA	0.18dB	52dBA	1.73dB	58dB	4.17dB

47dBA	0.39dB	53dBA	2.07dB	59dB	4.68dB
48dBA	0.61dB	54dBA	2.43dB	60dB	5.21dB
49dBA	0.86dB	55dBA	2.82dB		
50dBA	1.12dB	56dBA	3.25dB		

Note: The correction Factor shall be added to the limit of 60 dBA to arrive at the limit when the ambient is greater than 45 dBA

5.9 Field Observations: For new products field observation may be carried out by purchaser for the period of one month.

5.10 MTBF & MTTRPL:

I. **MTBF** of the system shall not be less than 100,000 hours. The MTBF for fans shall be better than 70,000 hours at 40°C. The concurrence of CACT in this regard is mandatory.

II. **Module Replacement Time:** The mean time to replace (MTTRPL) a faulty module (FR/FC, Inverter, CCU, Converter) shall be less than 2 minutes.

5.11 Environmental:

Each system shall be capable of operating in conditions conforming to TEC 14016:2010 (old no.QM-333:2010, category B2 or D whichever applicable). It shall also comply with vibration requirements of clause 12.0 of QM-333. The system shall also be capable of working in saline atmosphere of coastal areas and up to an altitude of 3000 Meters in compliance of QM-333.

6.0 EMI/ EMC

6.1 Radio Frequency Interference (RFI) Suppression

The system (FR/FC, CCU, INVERTER & DSCA modules) shall be designed to minimize the level of electromagnetic interference (EMI), both conducted and radiated, detected in its vicinity and generated by the module and shall comply the following clauses:

I. Conducted and Radiated Emission from the Power equipment.

Name of EMC Standard: CISPR 32 (2015) with A1 (2019)

“Electromagnetic compatibility of multimedia equipment – Emission requirements; Limits and methods of measurement of radio disturbance characteristics of Information Technology Equipment”.

Limits: -

- a) To comply with Class A of CISPR 32 (2015) with A1 (2019).
- b) The values of limits shall be as per relevant tables under CISPR 32 (2015) with A1 (2019).

II. Conducted Susceptibility Limits: Power equipment used in Telecom Network shall not malfunction when high voltage surge as specified below is superimposed at the input power mains to the power equipment, for more than two seconds as per IEC 61000- 4-18. The equipment shall also not fail or degrade in performance after the surge is withdrawn.

Test levels:

Voltage Rise time (First peak): 75 nano sec +/- 20%.

Oscillation Frequencies : 100 KHz & 1 MHz +/- 10%

Repetition rate : at least 40/s for 100KHz and 400/s for 1MHz

Decaying : 50% of the peak value between the 3rd & 6th periods

Burst duration : not less than 2 s

Surge amplitude : 250V (-10%) to 2.5 KV(+10%)

Wave shape : Damped

III. Electrostatic discharge (ESD) immunity limits: The limits shall be as per IEC 61000- 4-2, 9(1) (both Contact discharge method and Air discharge method) as given below:

Test level:

Contact discharge		Air discharge	
Level	Test voltage (KV)	Level	Test voltage (KV)
4	8	4	15

IV. Electrical fast transient/Burst immunity limits: The limits shall be as specified in IEC 61000-4-4.

Test level:

Open-circuit output test voltage (+/-10%) & repetition rate of impulses (+/- 20%)		
Level	On Power supply port, Protection Earth	
	Voltage peak KV	Repetition rate KHz
4	4	2.5
Rise time of one Pulse - 5 ns +/- 30%		
Impulse duration - 50 ns +/- 30%		

V. Radiated radio-frequency Electromagnetic field immunity limits: The limits as per IEC 61000-4-3.

Test level:

Frequency range : 80 MHz to 1000 MHz.	
Level	Test field strength V/m
3	10

VI. Surge immunity limits: The limits as per IEC 61000-4-5.

Test level:

Level	Open circuit test voltage(+/- 10%) KV
1	0.5
2	1.0
3	2.0
4	4.0
Voltage surge - 1.2/50 μ s Amplitude - 2 KV(DM) - 4 KV(CM) After testing for 4KV, the amplitude shall also be increased to 6 KV (1.2/50 μ s) Combined wave form as per IEEE C62.41- 1991 to cover Lightning/ Surge protection test also. - Test results shall be in compliance of clause 9(b) of IEC 61000-4-5.	

Note: The rated voltage of the MOVs shall not be less than 320V.

VII. Radio-Frequency Conducted Susceptibility immunity limits: The limits as per IEC 61000-4-6.

Test level:

Frequency range : 150 KHz- 80 MHz	
Level	Voltage level (e.m.f.)
3	10

7.0 SAFETY REQUIREMENTS

“The equipment shall conform to relevant safety requirements as per IS/ IEC 62368-1:2018 or Latest, as prescribed under Table no. 1 of the TEC document ‘SAFETY REQUIREMENTS OF TELECOMMUNICATION EQUIPMENT’: TEC10009: 2024.” The Manufacturer/supplier shall submit a certificate in respect of compliance to these requirements.

CHAPTER 2

8.0 GUIDELINE FOR THE PURCHASER/USER

This chapter describes the requirements which may be included in the tender by the purchaser as per its needs. The following items need to be specified by ordering authority depending upon the actual requirements:

- 8.1 The purchaser shall specify the rack dimension for any specific requirement. The type of rack – floor mounted or wall mounted – shall also be specified.
- 8.2 The purchaser may specify the requirement of field-trial. Feedback, if any, may be furnished to TEC for improvement in the GR.
- 8.3 The purchaser shall specify the requirements for optional management features like Battery Health Monitoring, Energy Saving Management, proper functioning during voltage and phase outages, DG Efficiency & Fuel Saving Management, Battery Efficiency & Battery Management, Rectifier Control – Efficiency Management, etc.
- 8.4 Purchaser/ Procurer shall specify the heat load inside the cabinet, maximum ambient temperature and target inside temperature to decide the capacity of cooling unit required.

As an example and for illustration purpose, Purchaser / Procurer may specify for cooling unit–

Active Cooling (Air- Conditioner)

- 1. Heat Load inside cabinet 1000W
- 2. Maximum Ambient temperature 45 °C
- 3. Target cabinet inside temperature (Average) $30 \pm 2^{\circ}\text{C}$

Passive Cooling (Refrigerant based Heat – Exchanger)

- 1. Heat Load inside cabinet 800W
- 2. Maximum Ambient temperature 45 °C
- 3. Target cabinet inside temperature (Average) $50 \pm 2^{\circ}\text{C}$

- 8.5** For TAC / Certification purpose, the OEM / Manufacturer shall demonstrate the outdoor weather proof rack of following minimum configuration, if not specifically mentioned by the Purchaser / Procurer:-

Active Cooling (Air- Conditioner)

1. Heat Load inside cabinet 1000W
2. Maximum Ambient temperature 45 °C
3. Target cabinet inside temperature (Average) $30 \pm 2^{\circ}\text{C}$

Passive Cooling (Refrigerant based Heat – Exchanger)

1. Heat Load inside cabinet 800W
2. Maximum Ambient temperature 45 °C
3. Target cabinet inside temperature (Average) $50 \pm 2^{\circ}\text{C}$

Door & Cable entry: one minimum MCT size (12/12) or similar sealing.

Usable U space can also be defined by purchaser at the time of purchase. For certification purpose (TSEC/ TAC etc) approval purpose 42U space shall be considered.

- 8.6** The Purchaser / Procurer shall furnish the details of their compressors indicating the MTBF, life of the compressor and continuous run time of the compressors without failure. Compressor shall have minimum of 1 years Warranty from the date of commissioning. Purchaser shall specify the extended warranty if needed.
- 8.7** Rating and number of MCBs shall be decided by purchaser.
- 8.8** The outdoor rack unit shall have operational life of 10 years normally subjected to mutual AMC agreement between the Purchaser / procurer and the OEM / Manufacturer.

- 8.9** Technical literature in English with complete layout, detailed block schematic and circuit diagrams of its assemblies shall be provided in hard copy. All aspects of installation, operation, maintenance, trouble shooting and replacement shall be covered in this manual. Additionally, a soft copy /QR code on the system in respect of technical literature shall also be provided both in Hindi and English .This manual can be provided as a soft copy or QR code and/ or hard copy as specified by the purchaser / procurer.
- 8.10** Some of the requirements mentioned in this document are to be decided by the Purchaser as mentioned in the respective clauses. The Purchaser/Procurer shall specify their requirements in those clauses.

9.0 ORDERING INFORMATION

The following items need to be specified while ordering by Tendering Authority depending on the requirements.

I. Cooling capacity required

II. (19"/21" etc.) Equipment space required inside the rack

III. Type of cooling unit required

IV. DCDB required

10.0 SPECIFIC ITEMS TO BE MENTIONED IN THE CERTIFICATE

Following details of product shall be mentioned on TAC-

1) MAKE AND Model number of the major parts- Cooling unit, Outdoor cabinet

Annexure 1

REMOTE MONITORING COMMUNICATION PROTOCOL – RS485 MODBUS

Baud Rate	9600
Data Bit	8
Stop Bit	1
Parity	None
Slave ID	1

Sr. No.	Parameters	Units of Measurement	Data Type (Float/Hex etc.)	Size in byte	Conversion Multiplier to read the data	Type of Register	Read/Write	Modbus Register Address	No. of Registers required	Remarks
INPUT REGISTER										
1	Product Type (Specified by purchaser)	NA	Unsigned Integer	2	1	Input Register	Read Only	1	1	Common
2	Product Make (Specified by OEM)	NA	Unsigned Integer	2	1	Input Register	Read Only	2	1	Common
3	SOFTWARE/FIRMWARE VERSION	Version	Unsigned Integer	2	0.1	Input Register	Read Only	3	1	Common
4	PROTOCOL VERSION	Version	Unsigned Integer	2	0.1	Input Register	Read Only	4	1	Common
5	PRODUCT SERIAL	NA	ASCII String	24	NA	Input Register	Read Only	5 ~ 16	12	Common

	NO. (Specified by OEM)									
6	SITE ID (Specified by purchaser)	NA	ASCII String	20	NA	Input Register	Read Only	17 ~ 26	10	Common
7	DATE of I&C (Specified by purchaser)	Date	Unsigne d Integer	2	1	Input Register	Read Only	27	1	Common
8	Internal fan1 revolution	RPM	Unsigne d Integer	2	1	Input Register	Read Only	28	1	Common
9	Internal fan2 revolution	RPM	Unsigne d Integer	2	1	Input Register	Read Only	29	1	Common
10	External fan1 revolution	RPM	Unsigne d Integer	2	1	Input Register	Read Only	30	1	Common
11	External fan2 revolution	RPM	Unsigne d Integer	2	1	Input Register	Read Only	31	1	Common
12	Compresso r Speed	RPM	Unsigne d Integer	2	1	Input Register	Read Only	32	1	Only applicabl e for Active cooling
13	Cabinet Air inlet temperatur e	Degree C	Unsigne d Integer	2	0.1 x degC	Input Register	Read Only	33	1	Common
14	Machine input voltage	Volt	Unsigne d Integer	2	0.1 x volts	Input Register	Read Only	34	1	Common
15	Cabinet inside return temperatur e	Degree C	Unsigne d Integer	2	0.1 x degC	Input Register	Read Only	35	1	Common
16	Condensin g temperatur e	Degree C	Unsigne d Integer	2	0.1 x degC	Input Register	Read Only	36	1	Only applicabl e for Active cooling

17	Run Hours of Only Hex	Hrs	Unsigned Integer	4		Input Register	Read Only	37~38	2	Only applicable for Passive cooling
18	Run Hours of Only Aircon	Hrs	Unsigned Integer	4		Input Register	Read Only	39~40	2	Only applicable for Active cooling
19	Spare		Unsigned Integer	2		Input Register	Read Only	41	1	
20	Spare		Unsigned Integer	2		Input Register	Read Only	42	1	
21	Spare		Unsigned Integer	2		Input Register	Read Only	43	1	
22	Spare		Unsigned Integer	2		Input Register	Read Only	44	1	
23	Spare		Unsigned Integer	2		Input Register	Read Only	45	1	
24	Spare		Unsigned Integer	2		Input Register	Read Only	46	1	
25	Spare		Unsigned Integer	2		Input Register	Read Only	47	1	
INPUT STATUS (Alarm- 1, No Alarm - 0)										
1	Internal Fan1 alarm	NA	BIT	NA	NA	Input Status	Read Only	1	1	Common
2	Internal Fan2 alarm	NA	BIT	NA	NA	Input Status	Read Only	2	1	Common
3	External fan1 alarm	NA	BIT	NA	NA	Input Status	Read Only	3	1	Common
4	External fan2 alarm	NA	BIT	NA	NA	Input Status	Read Only	4	1	Common
5	Compressors fail alarm	NA	BIT	NA	NA	Input Status	Read Only	5	1	Only applicable for Active cooling
6	Cabinet inside temperature sensor / Return temp sensor alarm	NA	BIT	NA	NA	Input Status	Read Only	6	1	Common

7	Ambient sensor alarm	NA	BIT	NA	NA	Input Status	Read Only	7	1	Common
8	Cabinet inside high temperature alarm	NA	BIT	NA	NA	Input Status	Read Only	8	1	Common
9	Cabinet inside low temperature alarm	NA	BIT	NA	NA	Input Status	Read Only	9	1	Common
10	High voltage alarm	NA	BIT	NA	NA	Input Status	Read Only	10	1	Common
11	Low voltage alarm	NA	BIT	NA	NA	Input Status	Read Only	11	1	Common
12	Door Open Alarm	NA	BIT	NA	NA	Input Status	Read Only	12	1	Common
13	F&S Alarm	NA	BIT	NA	NA	Input Status	Read Only	13	1	Common
14	Condensation temperature sensor alarming	NA	BIT	NA	NA	Input Status	Read Only	14	1	Only applicable for Active cooling
15	Internal fan1 status	NA	BIT	NA	NA	Input Status	Read Only	15	1	Common
16	Internal fan2 status	NA	BIT	NA	NA	Input Status	Read Only	16	1	Common
17	External fan1 status	NA	BIT	NA	NA	Input Status	Read Only	17	1	Common
18	External fan2 status	NA	BIT	NA	NA	Input Status	Read Only	18	1	Common
19	Machine Status	NA	BIT	NA	NA	Input Status	Read Only	19	1	Common
20	Compressor Status	NA	BIT	NA	NA	Input Status	Read Only	20	1	Only applicable for Active cooling
21	Spare	NA	BIT	NA	NA	Input Status	Read Only	21	1	
22	Spare	NA	BIT	NA	NA	Input Status	Read Only	22	1	

23	Spare	NA	BIT	NA	NA	Input Status	Read Only	23	1	
24	Spare	NA	BIT	NA	NA	Input Status	Read Only	24	1	
HOLDING REGISTER										
1	The external fan stopping temperature	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	1	1	Common
2	The external fan starting return temperature Difference	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	2	1	Common
3	Internal fans are starting return temperature difference	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	3	1	Common
4	The Internal fan stopping temperature	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	4	1	Common
5	Maximum Speed of Internal Fan	RPM	Unsigned Integer	2	1 x RPM	Holding Register	R/W	5	1	Common
6	Minimum Speed of Internal Fan	RPM	Unsigned Integer	2	1 x RPM	Holding Register	R/W	6	1	Common
7	Compressor setting Temperature	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	7	1	Only applicable for Active cooling
8	Compressor difference temperature	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	8	1	Only applicable for Active cooling

9	Heat Exchanger Starting temperature	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	9	1	Only applicable for Passive cooling
10	Heat Exchanger Stopping return difference temperature	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	10	1	Only applicable for Passive cooling
11	High temperature alarm point	Degree C	Unsigned Integer	2	0.1 x degC	Holding Register	R/W	11	1	Common
12	Low temperature alarm point	Degree C	Signed Integer	2	0.1 x degC	Holding Register	R/W	12	1	Common
13	Spare		Unsigned Integer	2		Holding Register	R/W	13	1	
14	Spare		Unsigned Integer	2		Holding Register	R/W	14	1	
15	Spare		Unsigned Integer	2		Holding Register	R/W	15	1	
16	Spare		Unsigned Integer	2		Holding Register	R/W	16	1	
17	High DC Voltage alarm point	Volt	Unsigned Integer	2	0.1 x Volt	Holding Register	R/W	17	1	Common
18	Low DC Voltage alarm point	Volt	Unsigned Integer	2	0.1x Volt	Holding Register	R/W	18	1	Common

Note: - Internal and External fan quantity to be decided by OEM

ABBREVIATIONS

A or Amps	Amperes
AC	Alternate Current
AH	Ampere Hour
AM	Air Mass
BIS	Bureau Of Indian Standards
CACT	Component Approval Centre of Telecommunication
CCU	Charge Controller Unit
CIGRE	International Conference on Large High Voltage Electric Systems
DB	Decibel
DBA	Decibel Absolute
DC	Direct Current
DEG C	Degrees Celsius
DG	Diesel Generator
DI	Digital Input
DOT	Department of Telecommunication
DSCA	Distribution, Switching, Control, Alarm and Monitoring Unit
E.M.F	Electro motive force
EMC	Electro Magnetic Compatibility
EMI	Electro Magnetic Interference
FET	Field Effect Transistor
GL/GG	General line/General Garcia (slow action fuses)
FSD	Full Scale Deflection
FR/FC	Float Rectifier cum Charger
FR/BC	Float Rectifier cum Battery Charger
GD	Gas Discharge
GR	Generic Requirements

IEC	International Electro-technical Commission
IS	Indian Standards
ISO	International Organization for Standardization
ITU-T	International Telecommunication Union-Transmission.
I-V	Current vs Voltage
Kg	Kilo Grams
KHz	Kilo Hertz
KW	Kilo Watts
LA	Flooded Type Lead Acid
LED	Light Emitting Diodes
LCD	Liquid Crystal Device
LM	Low Maintenance
MCB	Miniaturized Circuit Breaker
MHz	Mega Hertz
MIB	Management Information Base
MOV	Metal Oxide Varistor
MPPT	Maximum Power Point Tracking
MSL	Mean Sea Level
MTBF	Mean Time between Failures
MTTRPL	Mean Time To Replace
Ms	Milli seconds
NPL	National Physical Laboratories
OTA	Over the Air
PCB	Printed Circuit Board
PF	Power factor
PIV	Peak Inverse Voltage
PTC	Positive Temperature Co-efficient
PTC	Pulse Width Modulation

PWM	Pulse Width Modulation
QM	Quality Manual
RFI	Radio Frequency Interference
RTEC	Regional Telecom Engineering Centre
SMPS	Switch Mode Power Supply
SNMP	Simple Network Management Protocol
SPV	Solar Photo voltaic
SS	Self Supporting
T & D	Technical & Development
V	Volts
VDE	Verband Der Elektrootechniker
VRLA	Valve Regulated Lead Acid
W	Watts